

Part III Form 2
Section 11. ANNUAL REPORT.

Drinking-Water System Number:	220001156
Drinking-Water System Name:	MIDLAND WELL SUPPLY
Drinking-Water System Owner:	TOWN OF MIDLAND
Drinking-Water System Category:	CLASS 3 WATER DISTRIBUTION AND SUPPLY SYSTEM, CLASS 1 WATER TREATMENT SYSTEM
Period being reported:	JANUARY 01 2009 TO DECEMBER 31 2009

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>1- TOWN HALL 575 Dominion Ave Midland Ontario 2- Water and Wastewater Operations 200 Bay Street Midland Ontario 3- www.town.midland.on.ca</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p>
---	---

Indicate how you notified system users that your annual report is available, and is free of charge.

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office
- [] Public access/notice via a newspaper
- [X] Public access/notice via Public Request
- [] Public access/notice via a Public Library
- [] Public access/notice via other method

Describe your Drinking-Water System

The Town of Midland receives drinking water from five (5) Point of Entry well field areas, which utilize a total of thirteen (13) active groundwater wells throughout the municipality. Of these five (5) P.O.E. stations two (2) are GUDI sites. Well Site # 7 and Reservoir/Flume.

The distribution system consists of approximately 105 Km of water main including 5375 customer connections serving a population of 16,500. All P.O.E. are connected together throughout the distribution system including two (2) pressure zones and four (4) above ground storage facilities The groundwater system produced 2,439,301 m³ of drinking water for the reporting year of 2009.

List all water treatment chemicals used over this reporting period

Sodium Hypo chlorite - 12% Solution

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
June 22/2009	Free Residual	0.00	mg/L	Regained Free Residual	June 22/09
June 22/2009	Free Residual	0.00	mg/L	Regained Free Residual	June 22/09

#5 Harbourview Treatment System

Harbourview Groundwater Supply System

Consist of three (3) active wells and one standby well.

The Pump house

Located east of Sunnyside Drive;

NAD83: UTM Zone 17: 0587046.00m E, 4957076.00m N

houses the following equipment;

- two (2) high lift pumps rated for 9.47 L/s each vs 69 m TDH;
- two (2) chemical metering pumps (one duty and one standby) and one (1) 136 L sodium hypo chlorite storage tank.
- one (1) ultraviolet reactor system having a design dosage rate of 38 milli-joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus, monitoring and alarm systems.

A 100 mm diameter header and appurtenances connected to the feeder water main, including a propeller based flow meter.

Flow Capacity

- Maximum flow rate = 18.9 L/sec
- Maximum daily volume = 1,633 m³/d

List all water treatment chemicals used over the reporting period.

Sodium Hypo chlorite - 12% Solution

Where any significant expenses incurred during this reporting period to?

- Install required equipment **NO**
- Repair required equipment **NO**
- Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	153	Min 0 Max 0	Min 0 Max 0	0	N/A
Treated	51	Min 0 Max 0	Min 0 Max 0	51	< 10 cfu/mL – 30cfu/mL
Distribution	312	Min 0 Max 0	Min 0 Max 0	160	< 10 cfu/mL- 430 cfu/mL

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Min 0 NTU Max .70 NTU
Chlorine	8760	

***NOTE:** For continuous monitors use 8760 as the number of samples.*

#2 Highway 12 Treatment System
Highway 12 Groundwater Supply System

Consisting of two (2) active wells:

Well 7A is equipped with a vertical turbine pump, raw water flow meter and isolation valve.

Well 7B is equipped with a submersible well water pump, raw water flow meter, pitless adaptor and isolation valve.

The Pump house

Located south of Highway #12;

NAD83: UTM Zone 17: 0588713.00m E, 4953133.00m N

housing the following equipment;

-two (2) duty chemical metering pumps, and one (1) 500 L sodium hypo chlorite storage tank and discharge feed connections;

- two (2) ultraviolet reactor systems having a design dosage rate of 40 milli Jouls per centimeter squared (mJ/cm^2), with automatic cleaning apparatus monitoring and alarm system;

Discharge piping from the pump house to the Highway #12 existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

- one 330 kW Stand-by diesel generator supplying stand-by power for all pumps, analyzers, ultraviolet reactors and SCADA;

Well field Flow Capacity

- Maximum flow rate = 106 L/sec

- Maximum daily volume = 9,158 m^3/d

Well 7A is the firm well for the Midland Well Supply.

Where any significant expenses incurred during this reporting period to?

Install required equipment **NO**

Repair required equipment **NO**

Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	101	Min 0 Max 0	Min 0 Max 10	0	N/A
Treated	51	Min 0 Max 0	Min 0 Max 0	50	< 10 cfu/mL – 40 cfu/mL
Distribution	312	Min 0 Max 0	Min 0 Max 0	160	< 10 cfu/mL- > 450 cfu/mL

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Min 0.03 NTU Max 1.13 NTU
Chlorine	8760	

***NOTE:** For continuous monitors use 8760 as the number of samples.*

#1 Vindin Treatment System

Vindin Groundwater Supply System -G.U.D.I. Site

Consisting of six (6) active wells. Each well equipped with a submersible well water pump, pitless adaptor, raw water flow meter and isolation valve.

The Pump house

- one (1) split case centrifugal high lift pump rated for 37.9 L/s vs 85.3 m TDH;
- one (1) split case centrifugal high lift pump rated for 45.5 L/s vs 79.3 m TDH;
- one (1) in-line centrifugal high lift pump rated for 37.9 L/s vs 79.3 m TDH;
- two (2) ultraviolet reactor systems having a design dosage rate of 40 milli Joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus monitoring and alarm system;
- two (2) duty chemical metering pumps and one (1) 500 L sodium hypo chlorite storage tank;
- one (1) 330 kW Stand-by diesel generator supplying standby power for all pumps, analyzers, ultraviolet reactors and SCADA;

Discharge piping from the pump house to the existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Standby Generator

- 45 kW standby natural gas generator in separate building beside Well house #6 supplying standby power for four (4) wells.

Flow Capacity

- Maximum flow rate = 90.1 L/sec

- Maximum daily volume = 7,785 m³/d

Where any significant expenses incurred during this reporting period to?

Install required equipment **NO**

Repair required equipment **NO**

Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	302	Min 0 Max 0	Min 0 Max 0	0	N/A
Treated	51	Min 0 Max 0	Min 0 Max 0	51	< 10 cfu/mL – 260 cfu/mL
Distribution	312	Min 0 Max 0	Min 0 Max 0	160	< 10 cfu/mL- > 450 cfu/mL

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Min 0.07 NTU Max 0.97 NTU
Chlorine	8760	

***NOTE:** For continuous monitors use 8760 as the number of samples.*

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Flume	Result Value Well # 7	Unit of Measure
Antimony	07-Jan-09	<0.001	<0.001	mg/L
Arsenic	07-Jan-09	0.0006	0.0005	mg/L
Barium	07-Jan-09	0.079	0.118	mg/L
Boron	07-Jan-09	ND	ND	mg/L
Cadmium	07-Jan-09	<0.00002	<0.00002	mg/L
Chromium	07-Jan-09	<0.002	<0.002	mg/L
Lead	07-Jan-09	-	-	mg/L
Mercury	07-Jan-09	<0.00002	<0.00002	mg/L
Selenium	07-Jan-09	0.0007	0.0012	mg/L
Sodium	07-Jan-09	-	-	mg/L
Uranium	07-Jan-09	0.00142	0.00145	mg/L
Fluoride	07-Jan-09	-	-	mg/L
Nitrite	10-Oct-09	<0.1	<0.1	mg/L
Nitrate	10-Oct-09	0.4	1.6	mg/L

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Flume	Result Value Well # 7	Unit of Measure
Alachlor	07-Jan-09	<0.3	<0.3	ug/L
Aldicarb	07-Jan-09	<3	<3	ug/L
Aldrin + Dieldrin	07-Jan-09	<0.02	<0.02	ug/L
Atrazine + N-dealkylated metabolites	07-Jan-09	<0.5	<0.5	ug/L
Azinphos-methyl	07-Jan-09	<1	<1	ug/L
Bendiocarb	07-Jan-09	<3	<3	ug/L
Benzene	07-Jan-09	<0.5	<0.5	ug/L
Benzo(a)pyrene	07-Jan-09	<0.005	<0.005	ug/L
Bromoxynil	07-Jan-09	<0.03	<0.03	ug/L
Carbaryl	07-Jan-09	<3	<3	ug/L
Carbofuran	07-Jan-09	<1	<1	ug/L
Carbon Tetrachloride	07-Jan-09	<0.2	<0.2	ug/L
Chlordane (Total)	07-Jan-09	<0.04	<0.04	ug/L
Chlorpyrifos	07-Jan-09	<0.5	<0.5	ug/L
Cyanazine	07-Jan-09	<0.5	<0.5	ug/L
Diazinon	07-Jan-09	<1	<1	ug/L
Dicamba	07-Jan-09	<5	<5	ug/L
1,2-Dichlorobenzene	07-Jan-09	<0.1	<0.1	ug/L

1,4-Dichlorobenzene	07-Jan-09	<0.2	<0.2	ug/L
Dichlorodiphenyltric hloroethane (DDT) + metabolites	07-Jan-09	<0.1	<0.1	ug/L
1,2-Dichloroethane	07-Jan-09	<0.1	<0.1	ug/L
1,1-Dichloroethylene (vinylidene chloride)	07-Jan-09	<0.1	<0.1	ug/L
Dichloromethane	07-Jan-09	<0.3	<0.3	ug/L
2-4 Dichlorophenol	07-Jan-09	<0.1	<0.1	ug/L
2,4-Dichlorophenoxy acetic acid (2,4-D)	07-Jan-09	<5	<5	ug/L
Diclofop-methyl	07-Jan-09	<0.4	<0.4	ug/L
Dimethoate	07-Jan-09	<1	<1	ug/L
Dinoseb	07-Jan-09	<0.5	<0.5	ug/L
Diquat	07-Jan-09	<5	<5	ug/L
Diuron	07-Jan-09	<5	<5	ug/L
Glyphosate	07-Jan-09	<25	<25	ug/L
Heptachlor + Heptachlor Epoxide	07-Jan-09	<0.1	<0.1	ug/L
Lindane (Total)	07-Jan-09	<0.1	<0.1	ug/L
Malathion	07-Jan-09	<5	<5	ug/L
Methoxychlor	07-Jan-09	<0.1	<0.1	ug/L
Metolachlor	07-Jan-09	<3	<3	ug/L
Metribuzin	07-Jan-09	<3	<3	ug/L
Monochlorobenzene	07-Jan-09	<.02	<.02	ug/L
Paraquat	07-Jan-09	<1	<1	ug/L
Parathion	07-Jan-09	<3	<3	ug/L
Pentachlorophenol	07-Jan-09	<0.1	<0.1	ug/L
Phorate	07-Jan-09	<.03	<.03	ug/L
Picloram	07-Jan-09	<5	<5	ug/L
Polychlorinated Biphenyls(PCB)	07-Jan-09	<0.05	<0.05	ug/L
Prometryne	07-Jan-09	<.01	<.01	ug/L
Simazine	07-Jan-09	<.05	<.05	ug/L
THM (NOTE: show latest annual average)	07-Jan-09			ug/L
Temephos	07-Jan-09	<10	<10	ug/L
Terbufos	07-Jan-09	<.03	<.03	ug/L
Tetrachloroethylene	07-Jan-09			ug/L
2,3,4,6- Tetrachlorophenol	07-Jan-09	<0.1	<0.1	ug/L
Triallate	07-Jan-09	<10	<10	ug/L
Trichloroethylene	07-Jan-09	<0.2	<0.2	ug/L
2,4,6- Trichlorophenol	07-Jan-09	<0.1	<0.1	ug/L

2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	07-Jan-09	<10	<10	ug/L
Trifluralin	07-Jan-09	<0.5	<0.5	ug/L
Vinyl Chloride	07-Jan-09	<0.2	<0.2	ug/L

#4 Hanly Treatment System

Hanly Groundwater Supply System

Consisting of one (1) active well, equipped with a submersible well water pump, pitless adaptor and isolation valve.

The Pump house

Located at the southwest corner of Hanley Street and Russell Street;

NAD83: UTM Zone 17: 0589280.00m E, 4955008.00m N

- one (1) ultraviolet reactor system having a design dosage rate of 38 milli-Joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus, monitoring and alarm systems;

two (2) chemical metering pumps (one duty and one standby) and one (1) 200 L sodium hypo chlorite storage tank and discharge feed connections;

Discharge piping from the pump house to the Hanley Street existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Flow Capacity

- Maximum flow rate = 15.2 L/sec

- Maximum daily volume = 1,313 m³/d

Well 15 Point of Entry supplies treated water to the Lescaut Pressure Zone.

List all water treatment chemicals used over the reporting period.

Sodium Hypo chlorite - 12% Solution

Where any significant expenses incurred during this reporting period to?

Install required equipment **NO**

Repair required equipment **NO**

Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	51	Min 0 Max 0	Min 0 Max 0	0	N/A
Treated	51	Min 0 Max 0	Min 0 Max 0	52	< 10 cfu/mL – 20 cfu/mL
Distribution	312	Min 0 Max 0	Min 0 Max 0	160	< 10 cfu/mL- > 450 cfu/mL

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Min 0.05 NTU Max .83 NTU
Chlorine	8760	

NOTE: For continuous monitors use 8760 as the number of samples.

#3 Dominion Treatment System

Dominion Groundwater Supply System

Consisting of one (1) active well, equipped with a submersible well water pump, pitless adaptor and isolation valve.

The Pump house

Located at the southeast corner of Dominion Avenue and Old Penetanguishene Road
NAD83: UTM Zone 17: 0586348.00m E, 4954757.00m N

- one (1) ultraviolet reactor system having a design dosage rate of 38 milli-Joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus, monitoring and alarm systems;

two (2) chemical metering pumps (one duty and one standby) and one (1) 140 L sodium hypo chlorite storage tank and discharge feed connections;

- one (1) electric booster fire pump, fully alarmed and monitored, to supply a fire flow capacity of 91.4 L/sec vs 33.5 m TDH to the County Road #93 commercial distribution grid due west of the Pumping Station.

Discharge piping from the pump house to the existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Flow Capacity

- Maximum flow rate = 23 L/sec

- Maximum daily volume = 1,987 m³/d

Well 9 Point of Entry supplies treated water to the West Pressure Zone.

List all water treatment chemicals used over the reporting period.

Sodium Hypo chlorite - 12% Solution
--

Where any significant expenses incurred during this reporting period to?

- Install required equipment **NO**
- Repair required equipment **NO**
- Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	51	Min 0 Max 0	Min 0 Max 0	0	N/A
Treated	50	Min 0 Max 0	Min 0 Max 0	51	< 10 cfu/mL –2000 cfu/mL
Distribution	312	Min 0 Max 0	Min 0 Max 0	160	< 10 cfu/mL- > 2000 cfu/mL

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	Min 0.04 NTU Max .51 NTU
Chlorine	8760	

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Harbourview	Result Value Well #9	Result Value Well # 15	Unit of Measure
Antimony	09-Jan-08	ND	ND	ND	mg/L
Arsenic	09-Jan-08	.0002	0.0006	0.0005	mg/L
Barium	09-Jan-08	.033	0.140	.130	mg/L
Boron	09-Jan-08	.007	0.009	0.0009	mg/L
Cadmium	09-Jan-08	ND	ND	ND	mg/L
Chromium	09-Jan-08	ND	ND	ND	mg/L
Lead	09-Jan-08	ND	-	-	mg/L
Mercury	09-Jan-08	ND	ND	ND	mg/L
Selenium	09-Jan-08	0.0014	0.0020	0.0018	mg/L

Sodium	09-Jan-08	ND	-	-	mg/L
Uranium	09-Jan-08	0.00045	0.00152	0.00171	mg/L
Fluoride	09-Jan-08	5.1	-	-	mg/L
Nitrite	08-Oct-09	ND	ND	ND	mg/L
Nitrate	08-Oct-09	0.7	1.6	1.3	mg/L

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value Harbourview	Result Value Well #9	Result Value Well # 15	
Alachlor	09-Jan-08	ND	ND	ND	ug/L
Aldicarb	09-Jan-08	ND	ND	ND	ug/L
Aldrin + Dieldrin	09-Jan-08	ND	ND	ND	ug/L
Atrazine + N-dealkylated metabolites	09-Jan-08	ND	ND	ND	ug/L
Azinphos-methyl	09-Jan-08	ND	ND	ND	ug/L
Bendiocarb	09-Jan-08	ND	ND	ND	ug/L
Benzene	09-Jan-08	ND	ND	ND	ug/L
Benzo(a)pyrene	09-Jan-08	ND	ND	ND	ug/L
Bromoxynil	09-Jan-08	ND	ND	ND	ug/L
Carbaryl	09-Jan-08	ND	ND	ND	ug/L
Carbofuran	09-Jan-08	ND	ND	ND	ug/L
Carbon Tetrachloride	09-Jan-08	ND	ND	ND	ug/L
Chlordane (Total)	09-Jan-08	ND	ND	ND	ug/L
Chlorpyrifos	09-Jan-08	ND	ND	ND	ug/L
Cyanazine	09-Jan-08	ND	ND	ND	ug/L
Diazinon	09-Jan-08	ND	ND	ND	ug/L
Dicamba	09-Jan-08	ND	ND	ND	ug/L
1,2-Dichlorobenzene	09-Jan-08	ND	ND	ND	ug/L
1,4-Dichlorobenzene	09-Jan-08	ND	ND	ND	ug/L
Dichlorodiphenyltrichloroethane (DDT) + metabolites	09-Jan-08	ND	ND	ND	ug/L
1,2-Dichloroethane	09-Jan-08	ND	ND	ND	ug/L
1,1-Dichloroethylene (vinylidene chloride)	09-Jan-08	ND	ND	ND	ug/L
Dichloromethane	09-Jan-08	ND	ND	ND	ug/L
2,4-Dichlorophenol	09-Jan-08	ND	ND	ND	ug/L
2,4-Dichlorophenoxy acetic acid (2,4-D)	09-Jan-08	ND	ND	ND	ug/L

Diclofop-methyl	09-Jan-08	ND	ND	ND	ug/L
Dimethoate	09-Jan-08	ND	ND	ND	ug/L
Dinoseb	09-Jan-08	ND	ND	ND	ug/L
Diquat	09-Jan-08	ND	ND	ND	ug/L
Diuron	09-Jan-08	ND	ND	ND	ug/L
Glyphosate	09-Jan-08	ND	ND	ND	ug/L
Heptachlor + Heptachlor Epoxide	09-Jan-08	ND	ND	ND	ug/L
Lindane (Total)	09-Jan-08	ND	ND	ND	ug/L
Malathion	09-Jan-08	ND	ND	ND	ug/L
Methoxychlor	09-Jan-08	ND	ND	ND	ug/L
Metolachlor	09-Jan-08	ND	ND	ND	ug/L
Metribuzin	09-Jan-08	ND	ND	ND	ug/L
Monochlorobenzene	09-Jan-08	ND	ND	ND	ug/L
Paraquat	09-Jan-08	ND	ND	ND	ug/L
Parathion	09-Jan-08	ND	ND	ND	ug/L
Pentachlorophenol	09-Jan-08	ND	ND	ND	ug/L
Phorate	09-Jan-08	ND	ND	ND	ug/L
Picloram	09-Jan-08	ND	ND	ND	ug/L
Polychlorinated Biphenyls(PCB)	09-Jan-08	ND	ND	ND	ug/L
Prometryne	09-Jan-08	ND	ND	ND	ug/L
Simazine	09-Jan-08	ND	ND	ND	ug/L
THM	09-Jan-08		ND	ND	ug/L
Temephos	09-Jan-08	ND	ND	ND	ug/L
Terbufos	09-Jan-08	ND	ND	ND	ug/L
Tetrachloroethylene	09-Jan-08	ND	ND	ND	ug/L
2,3,4,6-Tetrachlorophenol	09-Jan-08	ND	ND	ND	ug/L
Triallate	09-Jan-08	ND	ND	ND	ug/L
Trichloroethylene	09-Jan-08	ND	ND	ND	ug/L
2,4,6-Trichlorophenol	09-Jan-08	ND	ND	ND	ug/L
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	09-Jan-08	ND	ND	ND	ug/L
Trifluralin	09-Jan-08	ND	ND	ND	ug/L
Vinyl Chloride	09-Jan-08	ND	ND	ND	ug/L