

Part III Form 2
Section 11. ANNUAL REPORT.

| | |
|--|--|
| Drinking-Water System Number: | 220001156 |
| Drinking-Water System Name: | MIDLAND WELL SUPPLY |
| Drinking-Water System Owner: | TOWN OF MIDLAND |
| Drinking-Water System Category: | CLASS 3 WATER DISTRIBUTION AND SUPPLY SYSTEM, CLASS 1 WATER TREATMENT SYSTEM |
| Period being reported: | JANUARY 01 2011 TO DECEMBER 31 2011 |

| | |
|---|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>1- TOWN HALL 575 Dominion Ave Midland Ontario</p> <p>2- Water and Wastewater Operations 200 Bay Street Midland Ontario</p> <p>3- www.town.midland.on.ca</p> </div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No []</p> <p>Number of Interested Authorities you report to: <input style="width: 100px; height: 20px;" type="text"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No []</p> |
|---|---|

Indicate how you notified system users that your annual report is available, and is free of charge.

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office
- [] Public access/notice via a newspaper
- [X] Public access/notice via Public Request
- [] Public access/notice via a Public Library
- [] Public access/notice via other method

Describe your Drinking-Water System

The Town of Midland receives drinking water from five (5) Point of Entry well field areas, one (1) of which is currently Offline, which utilize a total of thirteen (13) active groundwater wells throughout the municipality. Of these five (5) P.O.E. stations two (2) are GUDI sites. Well Site # 7, Reservoir/Flume, Hwy #12 Treatment System and Vindin Treatment Systems.

The distribution system consists of approximately 110 km of water main including 5,638 customer connection accounts serving a population of 16,700. All P.O.E. are connected together throughout the distribution system including two (2) pressure zones and four (4) above ground storage facilities The groundwater system produced 2,188,828 m³ of drinking water for the reporting year of 2011.

List all water treatment chemicals used over this reporting period

Sodium Hypo chlorite - 12% Solution

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
| April 10/11 | Low Cl2 | 0.00 | mg/L | Flushed | April 10/11 |

#5 Harbourview Treatment System *Currently OFFLINE*
#2 Highway 12 Treatment System
Highway 12 Groundwater Supply System

Consisting of two (2) active wells:

Well 7A is equipped with a vertical turbine pump, raw water flow meter and isolation valve.

Well 7B is equipped with a submersible well water pump, raw water flow meter, pitless adaptor and isolation valve.

The Pump house

Located south of Highway #12;

NAD83: UTM Zone 17: 0588713.00m E, 4953133.00m N

housing the following equipment;

-two (2) duty chemical metering pumps, and one (1) 500 L sodium hypo chlorite storage tank and discharge feed connections;

- two (2) ultraviolet reactor systems having a design dosage rate of 40 milli Jouls per centimeter squared (mJ/cm²), with automatic cleaning apparatus monitoring and alarm system;

Discharge piping from the pump house to the Highway #12 existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

- one 330 kW Stand-by diesel generator supplying stand-by power for all pumps, analyzers, ultraviolet reactors and SCADA;

Well field Flow Capacity

- Maximum flow rate = 106 L/sec
- Maximum daily volume = 9,158.4 m³/d

Well 7A is the firm well for the Midland Well Supply.

Where any significant expenses incurred during this reporting period to?

- Install required equipment **NO**
- Repair required equipment **NO**
- Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 96 | Min 0 Max 0 | Min 0 Max 10 | 0 | N/A |
| Treated | 51 | Min 0 Max 0 | Min 0 Max 0 | 51 | < 10 cfu/mL – 10 cfu/mL |
| Distribution | 330 | Min 0 Max 0 | Min 0 Max 0 | 171 | < 10 cfu/mL- >2000 cfu/mL |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|------------------|------------------------|----------------------------------|
| Turbidity | 8760 | Min 0.13 NTU Max 0.96 NTU |
| Chlorine | 8760 | |

***NOTE:** For continuous monitors use 8760 as the number of samples.*

#1 Vindin Treatment System

Vindin Groundwater Supply System -G.U.D.I. Site

Consisting of six (6) active wells. Each well equipped with a submersible well water pump, pitless adaptor, raw water flow meter and isolation valve.

The Pump house

- one (1) split case centrifugal high lift pump rated for 37.9 L/s vs 85.3 m TDH;
- one (1) split case centrifugal high lift pump rated for 45.5 L/s vs 79.3 m TDH;
- one (1) in-line centrifugal high lift pump rated for 37.9 L/s vs 79.3 m TDH;
- two (2) ultraviolet reactor systems having a design dosage rate of 40 milli Joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus monitoring and alarm system;
- two (2) duty chemical metering pumps and one (1) 500 L sodium hypo chlorite storage tank;
- one (1) 330 kW Stand-by diesel generator supplying standby power for all pumps, analyzers, ultraviolet reactors and SCADA;

Discharge piping from the pump house to the existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Standby Generator

- 45 kW standby natural gas generator in separate building beside Well house #6 supplying standby power for four (4) wells.

Flow Capacity

- Maximum flow rate = 90.1 L/sec
- Maximum daily volume = 7,785 m³/d

Where any significant expenses incurred during this reporting period to?

- Install required equipment **NO**
- Repair required equipment **NO**
- Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 306 | Min 0 Max 0 | Min 0 Max 0 | 0 | N/A |
| Treated | 51 | Min 0 Max 0 | Min 0 Max 0 | 51 | < 10 cfu/mL – 20 cfu/mL |
| Distribution | 330 | Min 0 Max 0 | Min 0 Max 0 | 171 | < 10 cfu/mL- >2000 cfu/mL |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|------------------|------------------------|----------------------------------|
| Turbidity | 8760 | Min 0.00 NTU Max 1.13 NTU |
| Chlorine | 8760 | |
| | | |

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value Flume | Result Value Well # 7 | Unit of Measure |
|-----------|-------------|--------------------|-----------------------|-----------------|
| Antimony | 03-Jan-11 | <0.001 | <0.001 | mg/L |
| Arsenic | 03-Jan-11 | 0.0003 | 0.0005 | mg/L |
| Barium | 03-Jan-11 | 0.109 | 0.112 | mg/L |
| Boron | 03-Jan-11 | ND | ND | mg/L |
| Cadmium | 03-Jan-11 | <0.00002 | <0.00002 | mg/L |

| | | | | |
|----------|-----------|----------|----------|------|
| Chromium | 03-Jan-11 | <0.002 | <0.002 | mg/L |
| Lead | 03-Jan-11 | - | - | mg/L |
| Mercury | 03-Jan-11 | <0.00002 | <0.00002 | mg/L |
| Selenium | 03-Jan-11 | <0.001 | <0.001 | mg/L |
| Sodium | 07-Jan-09 | 11 | 18 | mg/L |
| Uranium | 03-Jan-11 | 0.00133 | 0.00158 | mg/L |
| Fluoride | 07-Jan-09 | - | - | mg/L |
| Nitrite | 14-Oct-11 | <0.1 | <0.1 | mg/L |
| Nitrate | 14-Oct-11 | 0.8 | 0.4 | mg/L |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value Flume | Result Value Well # 7 | Unit of Measure |
|---|-------------|--------------------|-----------------------|-----------------|
| Alachlor | 07-Jan-09 | <0.3 | <0.3 | ug/L |
| Aldicarb | 07-Jan-09 | <3 | <3 | ug/L |
| Aldrin + Dieldrin | 07-Jan-09 | <0.02 | <0.02 | ug/L |
| Atrazine + N-dealkylated metabolites | 07-Jan-09 | <0.5 | <0.5 | ug/L |
| Azinphos-methyl | 07-Jan-09 | <1 | <1 | ug/L |
| Bendiocarb | 07-Jan-09 | <3 | <3 | ug/L |
| Benzene | 07-Jan-09 | <0.5 | <0.5 | ug/L |
| Benzo(a)pyrene | 07-Jan-09 | <0.005 | <0.005 | ug/L |
| Bromoxynil | 07-Jan-09 | <0.03 | <0.03 | ug/L |
| Carbaryl | 07-Jan-09 | <3 | <3 | ug/L |
| Carbofuran | 07-Jan-09 | <1 | <1 | ug/L |
| Carbon Tetrachloride | 07-Jan-09 | <0.2 | <0.2 | ug/L |
| Chlordane (Total) | 07-Jan-09 | <0.04 | <0.04 | ug/L |
| Chlorpyrifos | 07-Jan-09 | <0.5 | <0.5 | ug/L |
| Cyanazine | 07-Jan-09 | <0.5 | <0.5 | ug/L |
| Diazinon | 07-Jan-09 | <1 | <1 | ug/L |
| Dicamba | 07-Jan-09 | <5 | <5 | ug/L |
| 1,2-Dichlorobenzene | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| 1,4-Dichlorobenzene | 07-Jan-09 | <0.2 | <0.2 | ug/L |
| Dichlorodiphenyltrichloroethane (DDT) + metabolites | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| 1,2-Dichloroethane | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| 1,1-Dichloroethylene (vinylidene chloride) | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Dichloromethane | 07-Jan-09 | <0.3 | <0.3 | ug/L |
| 2-4 Dichlorophenol | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 07-Jan-09 | <5 | <5 | ug/L |
| Diclofop-methyl | 07-Jan-09 | <0.4 | <0.4 | ug/L |
| Dimethoate | 07-Jan-09 | <1 | <1 | ug/L |
| Dinoseb | 07-Jan-09 | <0.5 | <0.5 | ug/L |

| | | | | |
|--|-----------|-------|-------|------|
| Diquat | 07-Jan-09 | <5 | <5 | ug/L |
| Diuron | 07-Jan-09 | <5 | <5 | ug/L |
| Glyphosate | 07-Jan-09 | <25 | <25 | ug/L |
| Heptachlor + Heptachlor Epoxide | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Lindane (Total) | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Malathion | 07-Jan-09 | <5 | <5 | ug/L |
| Methoxychlor | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Metolachlor | 07-Jan-09 | <3 | <3 | ug/L |
| Metribuzin | 07-Jan-09 | <3 | <3 | ug/L |
| Monochlorobenzene | 07-Jan-09 | <.02 | <.02 | ug/L |
| Paraquat | 07-Jan-09 | <1 | <1 | ug/L |
| Parathion | 07-Jan-09 | <3 | <3 | ug/L |
| Pentachlorophenol | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Phorate | 07-Jan-09 | <.03 | <.03 | ug/L |
| Picloram | 07-Jan-09 | <5 | <5 | ug/L |
| Polychlorinated Biphenyls(PCB) | 07-Jan-09 | <0.05 | <0.05 | ug/L |
| Prometryne | 07-Jan-09 | <.01 | <.01 | ug/L |
| Simazine | 07-Jan-09 | <.05 | <.05 | ug/L |
| THM | 07-Jan-09 | - | - | ug/L |
| Temephos | 07-Jan-09 | <10 | <10 | ug/L |
| Terbufos | 07-Jan-09 | <.03 | <.03 | ug/L |
| Tetrachloroethylene | 07-Jan-09 | | | ug/L |
| 2,3,4,6-Tetrachlorophenol | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| Triallate | 07-Jan-09 | <10 | <10 | ug/L |
| Trichloroethylene | 07-Jan-09 | <0.2 | <0.2 | ug/L |
| 2,4,6-Trichlorophenol | 07-Jan-09 | <0.1 | <0.1 | ug/L |
| 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) | 07-Jan-09 | <10 | <10 | ug/L |
| Trifluralin | 07-Jan-09 | <0.5 | <0.5 | ug/L |
| Vinyl Chloride | 07-Jan-09 | <0.2 | <0.2 | ug/L |

#4 Hanly Treatment System

Hanly Groundwater Supply System

Consisting of one (1) active well, equipped with a submersible well water pump, pitless adaptor and isolation valve.

The Pump house

Located at the southwest corner of Hanly Street and Russell Street;

NAD83: UTM Zone 17: 0589280.00m E, 4955008.00m N

- one (1) ultraviolet reactor system having a design dosage rate of 38 milli-Joules per centimeter squared (mJ/cm^2), with automatic cleaning apparatus, monitoring and alarm systems;

two (2) chemical metering pumps (one duty and one standby) and one (1) 200 L sodium hypo chlorite storage tank and discharge feed connections;

Discharge piping from the pump house to the Hanly Street existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Flow Capacity

- Maximum flow rate = 15.2 L/sec
- Maximum daily volume = 1,313 m³/d

Well 15 Point of Entry supplies treated water to the Lescaut Pressure Zone.

List all water treatment chemicals used over the reporting period.

Sodium Hypo chlorite - 12% Solution

Where any significant expenses incurred during this reporting period to?

- Install required equipment **NO**
- Repair required equipment **NO**
- Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 52 | Min 0 Max 0 | Min 0 Max 0 | 0 | N/A |
| Treated | 51 | Min 0 Max 0 | Min 0 Max 0 | 51 | < 10 cfu/mL – 40cfu/mL |
| Distribution | 330 | Min 0 Max 0 | Min 0 Max 0 | 171 | < 10 cfu/mL- >2000 cfu/mL |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|------------------|------------------------|----------------------------------|
| Turbidity | 8760 | Min 0.06 NTU Max 0.86 NTU |
| Chlorine | 8760 | |

***NOTE:** For continuous monitors use 8760 as the number of samples.*

#3 Dominion Treatment System

Dominion Groundwater Supply System

Consisting of one (1) active well, equipped with a submersible well water pump, pitless adaptor and isolation valve.

The Pump house

Located at the southeast corner of Dominion Avenue and Old Penetanguishene Road
 NAD83: UTM Zone 17: 0586348.00m E, 4954757.00m N

- one (1) ultraviolet reactor system having a design dosage rate of 38 milli-Joules per centimeter squared (mJ/cm²), with automatic cleaning apparatus, monitoring and alarm systems;

two (2) chemical metering pumps (one duty and one standby) and one (1) 140 L sodium hypo chlorite storage tank and discharge feed connections;

- one (1) electric booster fire pump, fully alarmed and monitored, to supply a fire flow capacity of 91.4 L/sec vs 33.5 m TDH to the County Road #93 commercial distribution grid due west of the Pumping Station.

Discharge piping from the pump house to the existing water main, pump control valves, treated water flow meter, chlorine analyzer, turbidity analyzer and full S.C.A.D.A. control.

Flow Capacity

- Maximum flow rate = 23 L/sec

- Maximum daily volume = 1,987 m³/d

Well 9 Point of Entry supplies treated water to the West Pressure Zone.

List all water treatment chemicals used over the reporting period.

Sodium Hypo chlorite - 12% Solution

Where any significant expenses incurred during this reporting period to?

Install required equipment **NO**

Repair required equipment **NO**

Replace required equipment **NO**

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|---------------------|-------------------|--|---|-----------------------|--------------------------------------|
| Raw | 50 | Min 0 Max 0 | Min 0 Max 0 | 0 | N/A |
| Treated | 51 | Min 0 Max 0 | Min 0 Max 0 | 51 | < 10 cfu/mL –20 cfu/mL |
| Distribution | 330 | Min 0 Max 0 | Min 0 Max 0 | 171 | < 10 cfu/mL- >2000 cfu/mL |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min #)-(max #) |
|-----------|------------------------|----------------------------------|
| Turbidity | 8760 | Min 0.06 NTU Max 0.86 NTU |
| Chlorine | 8760 | |

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value Well #9 | Result Value Well # 15 | Unit of Measure |
|-----------|-------------|----------------------|------------------------|-----------------|
| Antimony | 13-Sep-11 | ND | ND | mg/L |
| Arsenic | 13-Sep-11 | 0.0006 | 0.0005 | mg/L |
| Barium | 13-Sep-11 | 0.168 | .151 | mg/L |
| Boron | 13-Sep-11 | 0.015 | 0.014 | mg/L |
| Cadmium | 13-Sep-11 | ND | ND | mg/L |
| Chromium | 13-Sep-11 | ND | ND | mg/L |
| Lead | 09-Jan-08 | - | - | mg/L |
| Mercury | 13-Sep-11 | ND | ND | mg/L |
| Selenium | 13-Sep-11 | 0.0020 | 0.0018 | mg/L |
| Sodium | 09-Jan-08 | 29 | 18 | mg/L |
| Uranium | 13-Sep-11 | 0.00152 | 0.00177 | mg/L |
| Fluoride | 05-Jan-05 | - | - | mg/L |
| Nitrite | 14-Oct-11 | ND | ND | mg/L |
| Nitrate | 14-Oct-11 | 1.6 | 1.4 | mg/L |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value Well #9 | Result Value Well # 15 | |
|--------------------------------------|-------------|----------------------|------------------------|------|
| Alachlor | 13-Sep-11 | ND | ND | ug/L |
| Aldicarb | 13-Sep-11 | ND | ND | ug/L |
| Aldrin + Dieldrin | 13-Sep-11 | ND | ND | ug/L |
| Atrazine + N-dealkylated metabolites | 13-Sep-11 | ND | ND | ug/L |
| Azinphos-methyl | 13-Sep-11 | ND | ND | ug/L |
| Bendiocarb | 13-Sep-11 | ND | ND | ug/L |
| Benzene | 13-Sep-11 | ND | ND | ug/L |
| Benzo(a)pyrene | 13-Sep-11 | ND | ND | ug/L |
| Bromoxynil | 13-Sep-11 | ND | ND | ug/L |
| Carbaryl | 13-Sep-11 | ND | ND | ug/L |

| | | | | |
|---|-----------|----|----|------|
| Carbofuran | 13-Sep-11 | ND | ND | ug/L |
| Carbon Tetrachloride | 13-Sep-11 | ND | ND | ug/L |
| Chlordane (Total) | 13-Sep-11 | ND | ND | ug/L |
| Chlorpyrifos | 13-Sep-11 | ND | ND | ug/L |
| Cyanazine | 13-Sep-11 | ND | ND | ug/L |
| Diazinon | 13-Sep-11 | ND | ND | ug/L |
| Dicamba | 13-Sep-11 | ND | ND | ug/L |
| 1,2-Dichlorobenzene | 13-Sep-11 | ND | ND | ug/L |
| 1,4-Dichlorobenzene | 13-Sep-11 | ND | ND | ug/L |
| Dichlorodiphenyltrichloroethane (DDT) + metabolites | 13-Sep-11 | ND | ND | ug/L |
| 1,2-Dichloroethane | 13-Sep-11 | ND | ND | ug/L |
| 1,1-Dichloroethylene (vinylidene chloride) | 13-Sep-11 | ND | ND | ug/L |
| Dichloromethane | 13-Sep-11 | ND | ND | ug/L |
| 2-4 Dichlorophenol | 13-Sep-11 | ND | ND | ug/L |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 13-Sep-11 | ND | ND | ug/L |
| Diclofop-methyl | 13-Sep-11 | ND | ND | ug/L |
| Dimethoate | 13-Sep-11 | ND | ND | ug/L |
| Dinoseb | 13-Sep-11 | ND | ND | ug/L |
| Diquat | 13-Sep-11 | ND | ND | ug/L |
| Diuron | 13-Sep-11 | ND | ND | ug/L |
| Glyphosate | 13-Sep-11 | ND | ND | ug/L |
| Heptachlor + Heptachlor Epoxide | 13-Sep-11 | ND | ND | ug/L |
| Lindane (Total) | 13-Sep-11 | ND | ND | ug/L |
| Malathion | 13-Sep-11 | ND | ND | ug/L |
| Methoxychlor | 13-Sep-11 | ND | ND | ug/L |
| Metolachlor | 13-Sep-11 | ND | ND | ug/L |
| Metribuzin | 13-Sep-11 | ND | ND | ug/L |
| Monochlorobenzene | 13-Sep-11 | ND | ND | ug/L |
| Paraquat | 13-Sep-11 | ND | ND | ug/L |
| Parathion | 13-Sep-11 | ND | ND | ug/L |
| Pentachlorophenol | 13-Sep-11 | ND | ND | ug/L |
| Phorate | 13-Sep-11 | ND | ND | ug/L |
| Picloram | 13-Sep-11 | ND | ND | ug/L |
| Polychlorinated Biphenyls(PCB) | 13-Sep-11 | ND | ND | ug/L |
| Prometryne | 13-Sep-11 | ND | ND | ug/L |
| Simazine | 13-Sep-11 | ND | ND | ug/L |

| | | | | |
|--|-----------|----|----|------|
| THM | 13-Sep-11 | ND | ND | ug/L |
| Temephos | 13-Sep-11 | ND | ND | ug/L |
| Terbufos | 13-Sep-11 | ND | ND | ug/L |
| Tetrachloroethylene | 13-Sep-11 | ND | ND | ug/L |
| 2,3,4,6-Tetrachlorophenol | 13-Sep-11 | ND | ND | ug/L |
| Triallate | 13-Sep-11 | ND | ND | ug/L |
| Trichloroethylene | 13-Sep-11 | ND | ND | ug/L |
| 2,4,6-Trichlorophenol | 13-Sep-11 | ND | ND | ug/L |
| 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) | 13-Sep-11 | ND | ND | ug/L |
| Trifluralin | 13-Sep-11 | ND | ND | ug/L |
| Vinyl Chloride | 13-Sep-11 | ND | ND | ug/L |

If you have any questions please direct them to the following contacts;

Tim Toole, Manager

Town of Midland

Water and Wastewater Operations

Tel. 705 526 4268 ext. 4200

Fax. 705 528 6072

tatoole@town.midland.on.ca

Mark Pinkney, Chief Operator

Town of Midland

Water and Wastewater Operations

Tel. 705 526 4268 ext. 4210

Fax. 705 528 6072

mpinkney@town.midland.on.ca